

UL-EU CERTIFICATE

Certificate No. UL-EU-01102-CPR
Page 1/7
Date of Issue 2018-12-19
Revised 2019-01-09

Certificate Holder Etex Building Performance Limited
Gordano House
Marsh Lane
Easton-in-Gordano
Bristol
BS20 0NE

Manufacturer A/021

Certified Product Type Fire Stop – Sealant
Product Trade Name PROMASEAL® -HPEx Sealant
Trademark N/A
Rating/Classification See Appendix

Expiry date 2028-12-18



A handwritten signature in purple ink, appearing to read 'Chris Miles', is written over a horizontal line.

Head of Notified Body
Chris Miles

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01102-CPR
Page 2/7
Date of Issue 2018-12-19

This certificate relates to the use of PROMASEAL® -HPEX Sealant for fire stopping where services penetrate floors and walls. The detailed scope is given in pages 3 to 6 of this Certificate. This shows the thickness and acceptable dimensions, substrates and orientations required to provide fire resistance periods of up to 240 minutes (EI 240).

The product is certificated on the basis of:

- i) Inspection and surveillance of factory production control by UL
- ii) Fire resistance test data in accordance with 1366-3: 2009
- iii) Classification in accordance with EN 13501-2
- iv) Durability and Servicability as defined in ETAG 026-2

The durability class of PROMASEAL® -HPEX Sealant is Z₁ - intended for use at internal conditions with high humidity, excluding temperatures below 0°C



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01102-CPR
 Page 3/7
 Date of Issue 2018-12-19

Product-type: Sealant (reactive)		Intended use: Penetration Seal
Basic requirement for construction work	Basic Requirement	Basic requirement for construction work
BWR 1 Mechanical resistance and stability		
-	None	-
BWR 2 Safety in case of fire		
EN 13501-1	Reaction to fire	Class F
EN 13501-2	Resistance to fire	See page 5
BWR 3 Hygiene, health and environment		
EN 1026:2000	Air permeability (material property)	See page 4
ETAG 026-3, Annex C	Water permeability (material property)	No performance determined
Declaration of manufacturer	Release of dangerous substances	Declaration of manufacturer
BWR 4 Safety in use		
EOTA TR 001:2003	Mechanical resistance and stability	No performance determined
EOTA TR 001:2003	Resistance to impact/movement	No performance determined
EOTA TR 001:2003 ISO 11600	Adhesion	No performance determined
BWR 5 Protection against noise		
EN 10140-2/ EN ISO 717-1	Airborne sound insulation	R _w (C;C _{tr})= 52(-1;-6)
EN 10140-3/ EN ISO 717-2	Impact sound insulation	No performance determined
BWR 6 Energy economy and heat retention		
EN 12664, EN 12667 or EN 12939	Thermal properties	No performance determined
EN ISO 12572 EN 12086	Water vapour permeability	No performance determined
General aspects relating to fitness for use		
ISO 8339: 2005, ISO 9046: 2004 & ISO 7389: 2003	Durability and serviceability	Z ₁
BWR 7 Sustainable use of natural resources		
-	-	No performance determined



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01102-CPR
Page 4/7
Date of Issue 2018-12-19

PROMASEAL® -HPEX Sealant: Air Permeability according to BS EN 1314-1				
Pressure (Pa)	Results under positive chamber pressure		Results under negative chamber pressure	
	Leakage (m ³ /h)	Leakage (m ³ /m ² /h)	Leakage (m ³ /h)	Leakage (m ³ /m ² /h)
50	0.2	5.6	0.3	8.3
100	0.4	11.1	0.6	16.7
150	0.7	19.4	0.9	25.0
200	1.0	27.8	1.2	33.3
250	1.1	30.6	1.6	44.4
300	1.2	33.3	1.9	52.8
450	2.2	61.1	2.7	75.0
600	2.4	66.7	3.4	94.4



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01102-CPR
 Page 5/7
 Date of Issue 2018-12-19

Substrate	Minimum Substrate Thickness (mm)	Seal annulus (mm)	Seal Position	Minimum Seal Depth (mm)	Backing Material	Service/insulation	Fire Resistance (mins.)			
							E	EI		
Drywall/ Masonry/ Concrete wall	120	10	Both sides	25	None	40 mm diameter PVC Pipe with 1.9-3mm wall thickness	120	120		
		16			Rock fibre mineral wool 30 mm deep and 80 kg/m ³	125 mm diameter PVC Pipe with 4.8-7.4mm wall thickness				
		300 x 100 (seal size)			None	63 mm diameter HDPE Pipe with 7.2mm wall thickness			120	120
		12.5				Electrical cables up to 21 mm diameter				
		20				90 mm diameter HDPE Pipe with 9.2mm wall thickness				
		15			90 mm diameter ABS Pipe with 6mm wall thickness	60 mm diameter Copper or Steel pipe with 0.8-14.2 mm wall thickness and insulated with 32 mm Armaflex AF*			120	90
	100	20		25	None	15 mm diameter Copper or Steel pipe with 0.8-7 mm wall thickness and insulated with 13 mm Armaflex AF*	120	120		
						40 mm diameter PVC Pipe with 1.9mm wall thickness	60	60		
						125 mm diameter PVC Pipe with 9.2mm wall thickness				
						40 mm diameter ABS Pipe with 1.9mm wall thickness	120	120		
						40 mm diameter HDPP Pipe with 2mm wall thickness				
						40 mm diameter Copper or Steel pipe with 1.5-14.2 mm wall thickness and insulated with 32 mm Armaflex AF**	120	30		
						40-159 mm diameter Copper or Steel pipe with 2.0-14.2 mm wall thickness and insulated with 32 mm Armaflex AF**				
						159 mm diameter Copper or Steel pipe with 2.0-14.2 mm wall thickness and insulated with 30 mm Pipelane SGR glass wool tube (80kg/m ³) **				

* Continuous through seal and full length of the pipe (CS)

** Continuous through seal and extending minimum 650 mm from both faces of the seal (LS)



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01102-CPR
 Page 6/7
 Date of Issue 2018-12-19

Substrate	Minimum Substrate Thickness (mm)	Seal annulus (mm)	Seal Position	Minimum Seal Depth (mm)	Backing Material	Service/insulation	Fire Resistance (mins.)	
							E	EI
Concrete floor	150	50 x 50 – 200 x 200 (seal size)	Upper face	25	Rock fibre mineral wool 100 mm deep and 45 kg/m ³	Electrical cables up to 21 mm diameter	180	120
						Electrical cables 22 to 80 mm diameter	120	120
						Non-sheathed electrical cables up to 24 mm diameter	180	15
						Telecomms cables up to 21 mm diameter (bundles up to 100 mm diameter)	180	20
		41-159 mm diameter Copper or Steel pipe with 2.5-14.2 mm wall thickness and insulated with 16-32 mm Armaflex AF*				120	120	
		50-110 mm diameter PP Pipe with 2.1 to 10.7 mm wall thickness				30	30	
		50 mm diameter PP Pipe with 2.1mm wall thickness				240	240	
		110 mm diameter PP Pipe with 10.7 mm wall thickness				120	120	
		40-125 mm diameter PE Pipe with 4.1 to 11.4 mm wall thickness				60	60	
		40 mm diameter PE Pipe with 4.1 mm wall thickness				240	240	
		125 mm diameter PE Pipe with 11.4 mm wall thickness				90	90	
		40-114 mm diameter PVC Pipe with 2.0 to 8.1 mm wall thickness				90	30	
		40 mm diameter PVC Pipe with 2.0 mm wall thickness				240	240	
		114 mm diameter PVC Pipe with 8.1 mm wall thickness				120	120	

* Continuous through seal and full length of the pipe (CS)



Appendix UL-EU CERTIFICATE

Certificate No. UL-EU-01102-CPR
Page 7/7
Date of Issue 2018-12-19

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.

