

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## Promat Retrofit Fire Collars\*

For partitions have been tested/approved in accordance with “Australian Standard 1530: Part 4

Methods for fire tests on building materials, components and structures” protecting

**Valsir Triplus®** pipe penetrations for a range of pipe sizes described below.

Collar	Pipe (mm)	Separating Element	FRL	Report
PROMASTOP® UniCollar	40	128mm thick FR plasterboard wall	-/180/180	26746500.2
	50		-/180/120	26746500.2
	70		-/180/120	26746500.2
	90		-/120/120	26746500.2
	100		-/180/120	26746500.2
	160		-/120/90	26746500.2

Collar	Pipe (mm)	Separating Element	FRL	Report
PROMASEAL FC Retrofit Collar	160	128mm thick FR plasterboard wall	-/180/120	26746500.2

Collar	Pipe (mm)	Separating Element	FRL	Report
PROMASTOP® UniCollar	40	78mm thick Speedpanel with 25mm PROMATECT® 100 or PROMATECT® 250 on each face	-/120/120	29592300 R4.0
	50		-/120/120	29592300 R4.0
	70		-/120/120	29592300 R4.0
	90		-/120/120	29592300 R4.0
	100		-/120/120	29592300 R4.0
	160		-/120/90	29592300 R4.0

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com](http://www.promat.com)

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## Promat Retrofit Fire Collars\*

For slab penetrations have been tested/approved in accordance with “Australian Standard 1530: Part 4 Methods for fire tests on building materials, components and structures” protecting

**Valsir Triplus®** pipe penetrations for a range of pipe sizes described below.

Collar	Pipe (mm)	Separating Element	FRL	Report
PROMASTOP® UniCollar	40	120mm thick concrete floor	-/240/120	26746500.2
	50		-/120/120	26746500.2
	70		-/120/120	26746500.2
	90		-/120/120	26746500.2
	100		-/180/120	26746500.2
	40	150mm thick concrete floor	-/240/120	26746500.2
	50		-/120/120	26746500.2
	70		-/120/120	26746500.2
	90		-/120/120	26746500.2
	100		-/180/180	26746500.2

Collar	Pipe (mm)	Separating Element	FRL	Report
PROMASEAL FC Retrofit Collar	160	150mm thick concrete floor	-/240/240	FRT190051.1

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com](http://www.promat.com)

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## Promat Cast-in Collars\*

For slab penetrations\* have been tested/approved in accordance with “Australian Standard 1530: Part 4 Methods for fire tests on building materials, components and structures” protecting **Valsir Triplus**® pipe penetrations for a range of pipe sizes described below.

Collar	Pipe (mm)	FRL			Report
		120mm Slab	150mm Slab	175mm Slab	
PROMASEAL® CIH 65 Cast-in Collar	40	-/240/240	-/240/240	-/240/240	45807.7
PROMASEAL® CIH 65 Cast-in Collar	50	-/240/240	-/240/240	-/240/240	45807.7
PROMASEAL® CIH 100 Cast-in Collar	70	-/180/120	-/240/240	-/240/240	45807.7
PROMASEAL® CIH 100 Cast-in Collar	90	-/180/120	-/240/240	-/240/240	45807.7
PROMASEAL® CIH 100 Cast-in Collar	100	-/180/120	-/240/240	-/240/240	45807.7
PROMASEAL® CIH 150 Cast-in Collar	150	-/180/180	-/180/180	-/180/180	45807.7

Collar	Pipe Diameter (mm)	Support Construction	FRL	Report
PROMASEAL® FWR Floor Waste Collar	100 (T-TRAP)	150mm thick concrete floor	-/240/240	A-17-090A
PROMASEAL® FWCH100 Floor Waste Collar High	100 (T-TRAP)	150mm thick concrete floor	-/240/240	A-18-011

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com](http://www.promat.com)