

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® Floor Waste Cast-in Collar

has been tested/approved in accordance with “Australian Standard 1530: Part 4
Methods for fire tests on building materials, components and structures”
and “Australian Standard 4072.1 Components for the protection of openings in fire
resistant separating elements Part 1: Service penetrations and control joints”

Penetrations in minimum 150mm concrete slab with PROMASEAL® FWC100 & FWC50/80

Service	Report	FRL
100mm uPVC with fitting	A-23-042	-/120/120
50mm uPVC with fitting	A-23-043	-/120/120
80mm uPVC with fitting	A-23-043	-/180/180



* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628) Email: PAPL.Mail@etexgroup.com Visit: <http://www.promat.com>

Head Office 1 Scotland Road, Mile End South, SA 5031 AUSTRALIA
New South Wales Office Unit 1, 175 Briens Road, Northmead, NSW 2152 AUSTRALIA
Victoria Office 355 Grieve Pde, Altona North VIC 3025 AUSTRALIA
Queensland Office 80 Stradbroke St, Heathwood QLD, 4110 AUSTRALIA