

Number of the declaration of performance: DoP010

1. Unique identification code of product-type: SSC

2. Intended use/es: For fire compartmentation and / or fire protection or performance, ETA 20/1144 and EAD 350454-00-1104

3. Manufacturer: FSi Limited, Westminster Industrial Estate, Tamworth Road, Measham, DE12 7DS, UK.

4. Authorised Representative: Not applicable

5. System/s of AVCP: AVCP - System 1

6b. European Assessment Document: EAD 350454-00-1104 - September 2017

European Technical Assessment: ETA 20/1144

Technical Assessment Body: ETA Denmark

Notified Body/ies: 2531


7. Declared performance:

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class F According to EN13501-1,
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 20/1144 clause 3.2 - Annex C
Dangerous Substances	See ETA 20/1145 Clause 3.5
Airbourne Sound Insulation	Tested in accordance with EN ISO 10140-2010 & EN ISO 717-1 See ETA 20/1144 Dn,ew (C;Ctr) = 52 (-4,-8)
Service & Durability	Z ¹ (0/+40 ^o c) intended for use at internal conditions with high humidity (85%) in accordance with EOTA technical documents TR024, Clause 3.12


8. Appropriate Technical Documentation and/or Specific Technical Documentation: ETA 20/1144

Link to the online copy of the declaration of performance: www.fsilttd.com

Signed for and on behalf of the manufacturer by:

 15/12/2021

.....
L.Peach - Technical Director

 15/12/2021

.....
M.Metcalfe - Firestop Manager