

**1. Unique identification code of product-type:**

PARA

**2. Type, Batch or serial number as required pursuant to Article 11(4):**

See ETA 21/0052 english : See batch number displayed in product

**3. Intended use or uses of construction product, in accordance with the applicable harmonized technical specification:**

Fire Stopping and Sealing Products for Linear Gap Seals, See ETA 21/0052

**4. Name, registered trade name or registered trade mark and contact address as required pursuant to article 11(5):**

FSi Limited, Westminster Industrial Estate, Tamworth Road, Measham, DE12 7DS, UK.

**5. Authorized representative:** N/A

**6. System or systems of assessment and verification of performance of the construction product as set out in Annex V:** AVCP - System 1

**7. Harmonized standard:** N/A

**8. In case of the declaration of performance concerning a construction product for which a Declaration of Performance has been issued:**

ETA Danmark issued European technical approval - ETA 21/0052 on the basis of EAD-350141-00-1106 Fire Stopping and Fire Sealing Products & issued certificate of conformity 2531-CPR-CX010122

**9. Declared performance:** Please refer to the table below (NPD - No Performance Determined)

Essential Characteristics	Performance/Harmonised technical specification
Reaction to Fire	Class A1 According to EN13501-1
Resistance to Fire	Resistance to fire performance & field of application in accordance with EN13051-2 See ETA 21/0052 clause 3.2 - Annex C
Air Permeability	Tested in accordance with EN 1026, See ETA 13/1070 Clause 3.3
Dangerous Substances	See ETA 21/0052 Clause 3.5
Airborne Sound Insulation	Tested in accordance with EN ISO 10140-2:2010 & EN ISO 140-3 & EN ISO 717-1 See ETA 21/0052 Clause 3.9 - Dne,w = 31dB
Service & Durability	Type Z <sub>2</sub> : Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV
Air Permeability	Tested in accordance with EN ISO 1026:2000. See ETA 21/0052 Annex B
Other	Not applicable/No performance determined

**10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 6. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.**

Signed for and on behalf of the manufacturer by:



27/07/2021

.....

L.Peach - Technical Director



27/07/2021

.....

M.Metcalfe - Firestop Manager