

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## Promat Fire Collars

For walls and floors have been tested/approved in accordance with “Australian Standard 1530:

Part 4 Methods for fire tests on building materials, components and structures” protecting

**George Fisher COOL-FIT 2.0** pipe penetrations for a range of pipe sizes described below.

Pipe Size	Collar	Separating Element	FRL	Report
32mm / 75mm	PROMASEAL FC 80	150mm Concrete Slab	-/240/240	FSP 2034
40mm / 90mm	PROMASEAL FC 100		-/240/240	FSP 2034
63mm / 110mm	PROMASEAL FC 100		-/240/240	FSP 2034
75mm / 125mm	PROMASEAL FC 150		-/240/240	FSP 2034

Pipe Size	Collar	Separating Element	FRL	Report
32mm / 75mm	PROMASEAL FC 80	2x13mm FR Plasterboard on 64mm stud	-/120/120	FSP 2022
40mm / 90mm	PROMASEAL FC 100		-/120/120	FSP 2022
63mm / 110mm	PROMASEAL FC 100		-/120/120	FSP 2022

Pipe Size	Collar	Separating Element	FRL	Report
32mm / 75mm	PROMASEAL FC 80	78mm Speedpanel + 25mm PROMATECT 250 each side	-/120/120	FSP 2021
40mm / 90mm	PROMASEAL FC 100		-/120/120	FSP 2021
63mm / 110mm	PROMASEAL FC 100		-/120/120	FSP 2021
75mm / 125mm	PROMASEAL FC 150		-/120/120	FSP 2021

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)