

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMAT Fire Collars

As described below

For 128mm lightweight or rigid walls, 78mm Speedpanel Walls and 150mm slab penetrations have been tested/approved in accordance with “Australian Standard 1530: Part 4 Methods for fire tests on building materials, components and structures” protecting Rehau RAUPIANO PLUS® pipe penetrations for a range of pipe sizes described below.

(Test/Approval No. FAS180527, 29592300.4, 26149-R6.1, A-16-066, A-17-029A, A-19-014, A-21-043)

Pipe Diameter	Construction	Collar	FRL
40	Floor / Slab	PROMASEAL® CIL 40	-/240/180
	Floor / Slab	PROMASTOP® UniCollar	-/240/120
	Floor / Slab	PROMASEAL® CIH 65	-/120/120
	Plasterboard / Rigid Wall	PROMASTOP® UniCollar	-/240/180
	Speedpanel Wall	PROMASTOP® UniCollar	-/120/120 ⁽⁴⁾
50	Floor / Slab	PROMASEAL® CIL 50 / CIH 65	-/240/180
	Floor / Slab	PROMASTOP® UniCollar	-/120/120
	Plasterboard Wall	PROMASTOP® UniCollar	-/240/120
	Speedpanel Wall	PROMASTOP® UniCollar	-/120/120 ⁽⁴⁾
75	Floor / Slab	PROMASEAL® CIL 80	-/240/240 ⁽¹⁾
	Floor / Slab	PROMASEAL® CIH 65	-/240/180
	Floor / Slab	PROMASTOP® UniCollar	-/120/120
	Plasterboard / Rigid Wall	PROMASTOP® UniCollar	-/240/120
	Speedpanel Wall	PROMASTOP® UniCollar	-/120/120 ⁽⁴⁾

⁽¹⁾ PROMASEAL Graf 4T installed in the collar, ⁽²⁾ Floor waste with 4-way riser, ⁽³⁾ Floor waste with S-trap ⁽⁴⁾ Thickened with PROMATECT 250 – 25mm

For results in thinner slabs, contact Promat

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628) Email: PAPL.mail@etexgroup.com Visit: www.promat.com

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMAT Fire Collars

As described below

For 128mm lightweight or rigid walls, 78mm Speedpanel Walls and 150mm slab penetrations have been tested/approved in accordance with “Australian Standard 1530: Part 4 Methods for fire tests on building materials, components and structures” protecting Rehau RAUPIANO PLUS® pipe penetrations for a range of pipe sizes described below.

(Test/Approval No. FAS180527 R1.2, 29592300.4, 26149-R6.1, A-16-066, A-17-029A, A-19-014)

Pipe Diameter	Construction	Collar	FRL
90	Floor / Slab	PROMASEAL® CIL 100	-/180/180
	Floor / Slab	PROMASTOP® UniCollar	-/120/120
	Plasterboard / Rigid Wall	PROMASTOP® UniCollar	-/120/120
	Speedpanel Wall	PROMASTOP® UniCollar	-/120/120 ⁽⁴⁾
110	Floor / Slab	PROMASEAL® CIL 100	-/180/180
	Floor / Slab	PROMASEAL® CIH 100	-/180/120
	Floor / Slab	PROMASTOP® UniCollar	-/180/120
	Plasterboard / Rigid Wall	PROMASTOP® UniCollar	-/240/120
	Speedpanel Wall	PROMASTOP® UniCollar	-/120/120 ⁽⁴⁾
110 (Floor Waste)	Floor / Slab	PROMASEAL® FWC100	-/240/240 ⁽²⁾
	Floor / Slab	PROMASEAL® FWC100H	-/240/240 ⁽²⁾
	Floor / Slab	PROMASEAL® FWR	-/240/240 ⁽³⁾
160	Floor / Slab	PROMASEAL® FC 150	-/240/180
	Plasterboard / Rigid Wall	PROMASEAL® FC 150	-/240/180
200	Floor / Slab	PROMASEAL® FC 250	-/240/120
	Plasterboard / Rigid Wall	PROMASEAL® FC 250	-/240/180

⁽¹⁾ PROMASEAL Graf 4T installed in the collar, ⁽²⁾ Floor waste with 4-way riser, ⁽³⁾ Floor waste with S-trap ⁽⁴⁾ Thickened with PROMATECT 250 – 25mm

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: PAPL.mail@etexgroup.com Visit: www.promat.com