

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® Bulkhead Sealer System

For barriers has been tested/approved in accordance with “Australian Standard 1530: Part 4 Methods for fire tests on building materials, components and structures”

Aperture sizes in Masonry, Concrete, AAC or Plasterboard Walls (Assessment 25948-05)

Barrier	Size	Batt Thickness	FRL
PROMASEAL® Bulkhead Batts fitted to aperture	600mm high x 1500mm wide	2 x 50mm thick	-/120/120
	Max 1000mm high and any width to a max area of 1.0m ²		-/120/120
	500mm high x infinite width		-/120/120

Aperture sizes in Speedpanel Walls (Test Report FSRG A-15-982)

Barrier	Size	Batt Thickness	FRL
PROMASEAL® Bulkhead Batts fitted to aperture	450mm high x 550mm wide	2 x 50mm thick	-/120/120

Aperture sizes in Concrete Floors (Assessment 25948-05)

Barrier	Size	Batt Thickness	FRL
PROMASEAL® Bulkhead Batts fitted to aperture	600mm wide x 1500mm long	2 x 50mm thick	-/120/120
	600mm wide x infinite length (supported at 600mm centers)		-/120/120
	300mm wide x infinite length		-/120/120

Aperture sizes in 100mm Bondor Flameguard (Test Report 2668900.2)

Barrier	Size	Batt Thickness	FRL
PROMASEAL® Bulkhead Batts fitted to aperture	600mm wide x 600mm long	2 x 50mm thick	-/120/120

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® Bulkhead Sealer System

For barriers and wall/floor penetrations
have been tested/approved in accordance with
“Australian Standard 1530: Part 4

Methods for fire tests on building materials, components and structures”

Service Penetrations in Masonry, Concrete, AAC or Plasterboard Walls
(Assessments 25948-05, 45697.2. Test Reports FSRG A-14-874, FSRG A-15-974)

Barrier	Service	Protection	FRL
PROMASEAL® Bulkhead Batts fitted to aperture (2 x 50mm thick)	50mm Copper Pipe lagged with 25mm thick FR Armaflex	PROMASEAL® FlexiWrap	-/180/90
	Brass Pipes Ø32mm to Ø100mm	Single pipe protected with 25mm PROMASEAL® Wrap 800mm each side of the wall	-/120/120
	Copper, Steel & Iron Ø32mm to Ø150mm		-/120/120
	Copper Pipe Ø19mm wrapped Armaflex & 6mm PROMASEAL® FlexiWrap fitted within steel sleeve		-/120/120
	Trefoil Copper Pipe Ø19mm wrapped Armaflex & 6mm PROMASEAL® FlexiWrap fitted within steel sleeve	Bundle protected with 25mm PROMASEAL® Wrap 800mm each side of the wall	-/120/120
	uPVC pipe Ø40mm to Ø100mm	PROMASEAL® FCW Wall Collar	-/120/120
	HDPE pipe Ø40mm to Ø100mm		-/120/120
	uPVC pipe Ø40mm	PROMASEAL® FC 40	-/120/120
	uPVC pipe Ø100mm	PROMASEAL® FC 100	-/120/120
	HDPE pipe Ø 40mm	PROMASEAL® FC 40	-/180/180
	HDPE pipe Ø 100mm	PROMASEAL® FC 100	-/180/180
	PEX pipe Ø20mm	PROMASEAL® CFC	-/120/120
	AS1530.4: 2005 Appendix D, D1 and D2 cables	Cables protected with 25mm PROMASEAL® Wrap 800mm each side of the wall	-/120/120
	Cable trunking and cables		-/120/120
	Cable bundle Ø60mm	PROMASEAL® AN Acrylic Sealant	-/120/120
	Cable bundle Ø30mm		-/120/120
Fibre Optic bundle Ø60mm	-/180/180		

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® Bulkhead Sealer System

For barriers and wall/floor penetrations
 have been tested/approved in accordance with
 "Australian Standard 1530: Part 4

Methods for fire tests on building materials, components and structures"

Service Penetrations through Bulkhead Batt System in Floors (Assessment 25948-05)

Barrier	Service	Protection	FRL
PROMASEAL® Bulkhead Batts fitted to aperture (2 x 50mm thick)	Brass Pipes Ø32mm to Ø100mm	Single pipe protected with 25mm PROMASEAL® Wrap 800mm each side of the wall	-/120/120
	Copper, Steel & Iron Ø32mm to Ø150mm		-/120/120
	Copper Pipe Ø19mm wrapped Armaflex & 6mm PROMASEAL® FlexiWrap fitted within steel sleeve		-/120/120
	AS1530.4: 2005 Appendix D, D1 and D2 cables	Cables protected with 25mm PROMASEAL Wrap 800mm each side of the wall	-/120/120
	Cable trunking and cables	-/120/120	



* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® Bulkhead Sealer System

For barriers and wall/floor penetrations
have been tested/approved in accordance with
“Australian Standard 1530: Part 4

Methods for fire tests on building materials, components and structures”

Service Penetrations in 90mm thick FR Plasterboard partitions (Test Report FSRG A-15-973)

Barrier	Service	Protection	FRL
PROMASEAL® Bulkhead Batts fitted to aperture (1 x 50mm thick)	50mm uPVC	PROMASEAL® FC 50	-/60/60
	100mm uPVC	PROMASEAL® FC 100	-/60/60
	25mm diameter bunch of 2.5mm twin and earth cables (4 cables)	50mm x 50mm cone of PROMASEAL® AN Acrylic Sealant	-/60/60



* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au