

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMASEAL® FC Retrofit Collars

For concrete floors have been tested/approved in accordance with “Australian Standard 1530: Part 4: 2005

Methods for fire tests on building materials, components and structures”
protecting uPVC and HDPE pipe penetrations

(Refer to assessment EWFA 29592300.1)

Pipe Material	Pipe Size (DN)	Protection	FRL
uPVC	40	PROMASEAL® FC 40	-/240/120
	50	PROMASEAL® FC 50	-/240/120
	65	PROMASEAL® FC 65	-/240/120
	80	PROMASEAL® FC 80	-/240/120
	100	PROMASEAL® FC 100	-/240/120
	150	PROMASEAL® FC 150	-/240/120
	250	PROMASEAL® FC 250	-/240/120
	300	PROMASEAL® FC 300	-/240/120
HDPE	40	PROMASEAL® FC 40	-/240/120
	50	PROMASEAL® FC 50	-/180/120
	63	PROMASEAL® FC 65	-/240/120
	75	PROMASEAL® FC 80	-/240/120
	110	PROMASEAL® FC 100	-/240/120
	150	PROMASEAL® FC 150	-/180/120
	250	PROMASEAL® FC 250	-/240/120
	320	PROMASEAL® FC 300 ⁽¹⁾	-/120/120



⁽¹⁾ FRL achieved in 170mm concrete slab

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au

Head Office

New South Wales Office

Victoria Office

Queensland Office

1 Scotland Road, Mile End South, SA 5031 AUSTRALIA

Unit 1, 175 Briens Road, Northmead, NSW 2152 AUSTRALIA

Suite 205, 198 Harbour Esplanade, Docklands, VIC 3008 AUSTRALIA

1/68 Lisgar Street, Virginia, QLD 4014 AUSTRALIA

an etex company